

**CORRIGENDUM No. 3**

Sub: Renovation of 3rd, 4th, 5th, & 6th Floor of Service Block-including Civil, Plumbing, Furniture, Electrical, HVAC & Fire fighting system work at MDL, Mumbai.

Ref: Tender No. 180000038 dated 20 April' 17

The following points shall be considered by the bidder(s) before submission of final offer for the subject tender.

Item No. of TEF Vol-III	Item Description	Page No.	Queries from Bidder	Additional/Corrected Description (To be change in respective item description)
41	Finishing: GYPSUM : 12.5mm thk Gypsum on one side fixed to plywood skin with glue having joints and grooves as shown or directed. (Basic Rate of Gypsum Board Rs. 600/- Sqmt)	25 of Vol-III	To review basic rates of item.	GYPSUM : 12.5mm thk Gypsum on one side fixed to plywood skin with glue having joints and grooves as shown or directed. (Basic rate of Gypsum board of Rs. 207.00 Sqmt)
44	Finishing: MOISTURE RESISTANT GYPSUM : 12.5mm thk Gypsum on one side fixed to plywood skin with glue having joints and grooves as shown or directed. (Basic rate of Gypsum Rs. 750/- Sqmt)	25 of Vol-III	To review basic rates of item.	MOISTURE RESISTANT GYPSUM : 12.5mm thk Gypsum on one side fixed to plywood skin with glue having joints and grooves as shown or directed. (Basic rate of Moisture resistant Gypsum board of Rs. 369.00 Sqmt)
58	Providing and fixing 75mm deep including 1000 to 1050mm deep fascia using 12mm thick marine ply & 12mm thick 12.5mm thick Gypsum board backing with approved paint with teakwood beading around the edge with aluminium framework of size 50 X 50 X 1.5mm @ 450mm C/C etc. complete as per design or as directed.	27 of Vol-III	To review basic rates of item.	Providing and fixing 75mm deep including 1000 to 1050mm deep fascia using 12mm thick marine ply & 12mm thick 12.5mm thick Gypsum board backing with approved paint with teakwood beading around the edge with aluminium framework of size 50 X 50 X 1.5mm @ 450mm C/C etc. complete as per design or as directed. (Basic rate of Gypsum board of Rs. 207.00 Sqmt)
72	Providing and fixing false ceiling at all height including providing and fixing of frame work made of special sections, power pressed from M.S. sheets and galvanized with zinc coating of 120 gms/sqm (both side inclusive) as per IS : 277 and consisting of angle cleats of size 25 mm wide x 1.6 mm thick with flanges of 27 mm and 37mm, at 1200 mm centre to centre, one flange fixed to the ceiling with dash fastener 12.5 mm dia x 50mm long with 6mm dia bolts, other flange of cleat fixed to the angle hangers of 25x10x0.50 mm of required	30 of Vol-III	To review basic rates of item.	Providing and fixing false ceiling at all height including providing and fixing of frame work made of special sections, power pressed from M.S. sheets and galvanized with zinc coating of 120 gms/sqm (both side inclusive) as per IS : 277 and consisting of angle cleats of size 25 mm wide x 1.6 mm thick with flanges of 27 mm and 37mm, at 1200 mm centre to centre, one flange fixed to the ceiling with dash fastener 12.5 mm dia x 50mm long with 6mm dia bolts, other flange of cleat fixed to the angle hangers of 25x10x0.50 mm of required



	<p>length with nuts & bolts of required size and other end of angle hanger fixed with intermediate G.I. channels 45x15x0.9 mm running at the spacing of 1200 mm centre to centre, to which the ceiling section 0.5 mm thick bottom wedge of 80 mm with tapered flanges of 26 mm each having lips of 10.5 mm, at 450 mm centre to centre, shall be fixed in a direction perpendicular to G.I. intermediate channel with connecting clips made out of 2.64 mm dia x 230 mm long G.I. wire at every junction, including fixing perimeter channels 0.5 mm thick 27 mm high having flanges of 20 mm and 30 mm long, the perimeter of ceiling fixed to wall/partition with the help of rawl plugs at 450 mm centre, with 25mm long dry wall screws @ 230 mm interval, including fixing of gypsum board to ceiling section and perimeter channel with the help of dry wall screws of size 3.5 x 25 mm at 230 mm c/c, including jointing and finishing to a flush finish of tapered and square edges of the board with recommended jointing compound , jointing tapes , finishing with jointing compound in 3 layers covering upto 150 mm on both sides of joint and two coats of primer suitable for board, all as per manufacturer's specification and also including the cost of making openings for light fittings, grills, diffusers, cutouts made with frame of perimeter channels suitably fixed, all complete as per drawings, specification and direction of the Engineer in Charge but excluding the cost of painting with :</p> <p>--12.5 mm thick tapered edge gypsum plain board conforming to IS: 2095- Part I (Basic rate of Gypsum of Rs. 600/-Sq.mt)</p>			<p>length with nuts & bolts of required size and other end of angle hanger fixed with intermediate G.I. channels 45x15x0.9 mm running at the spacing of 1200 mm centre to centre, to which the ceiling section 0.5 mm thick bottom wedge of 80 mm with tapered flanges of 26 mm each having lips of 10.5 mm, at 450 mm centre to centre, shall be fixed in a direction perpendicular to G.I. intermediate channel with connecting clips made out of 2.64 mm dia x 230 mm long G.I. wire at every junction, including fixing perimeter channels 0.5 mm thick 27 mm high having flanges of 20 mm and 30 mm long, the perimeter of ceiling fixed to wall/partition with the help of rawl plugs at 450 mm centre, with 25mm long dry wall screws @ 230 mm interval, including fixing of gypsum board to ceiling section and perimeter channel with the help of dry wall screws of size 3.5 x 25 mm at 230 mm c/c, including jointing and finishing to a flush finish of tapered and square edges of the board with recommended jointing compound , jointing tapes , finishing with jointing compound in 3 layers covering upto 150 mm on both sides of joint and two coats of primer suitable for board, all as per manufacturer's specification and also including the cost of making openings for light fittings, grills, diffusers, cutouts made with frame of perimeter channels suitably fixed, all complete as per drawings, specification and direction of the Engineer in Charge but excluding the cost of painting with :</p> <p>--12.5 mm thick tapered edge gypsum plain board conforming to IS: 2095- Part I (Basic rate of Gypsum board of Rs. 207.00 Sqmt)</p>
110	Supply. Installation, Testing & Commissioning of the Track 1 Meter 3 Phase White. (Display Room)	39 of Vol-III	Instead of Track 1 meter 3 phase can we quote for single phase	Tender BOQ holds good.



			track	
116, 169, 216 & 263	SITC of battery operated call bell system with receiver unit with indicator & buzzing sound of approved make.	40, 48, 55 & 62 of Vol- III	The number of receivers to be operated on one call bell system	The Stand alone type Call bell system i.e. individual receiver for each Call bell system is specified.

2. The closing date of the Tender is extended from **06 June' 17** to **13 June' 2017 at 1430 hrs** and Opening date of the Tender extended from **07 June' 17** to **14 June' 2017 at 1430 hrs**.
3. All other terms & conditions remain unaltered.
4. The Corrigendum-3 as above, duly signed & stamped, shall be scanned and submitted along with Techno-commercial Bid (PART-I) of the offer.

Signature of Contractor

Seal

Date